Selected interior lining

65 x 2.8mm RounDrive ring shank nails for batten fixing

Selected coating

Axon™ Panel

Seal with Bostik® Seal n Flex® - 1 or Sika® Sikaflex® 11FC adhesive sealant

70 x 19mm Hardie™ CLD™ Structural Cavity Batten

HomeRAB™ Pre-Cladding/RAB™ Board

Hardie™ 9mm aluminium angle 'T' socket

Prime top of panel prior to socket installation

Apply two 6mm thick lines of adhesive sealant on the bottom portion of the Hardie™ 9mm aluminium angle 'T' socket to seal

C - 25mm 'T' head stainless steel brad nails for panel fixing

65 x 2.8mm RounDrive ring shank nails for batten fixing

150mm long horizontal Hardie™ CLD™ packers optional between vertical battens when battens are fixed over studs at 600mm apart. Packers must be set to a fall of 5° min.

10mm gap

Axon™ Panel
On Hardie™ CLD™ Structural Cavity Batten with HomeRAB™
Pre-Cladding/RAB™ Board
HORIZONTAL JOINT IN TALL WALL

March 2024
Scale: 1 : 2

Figure 35