



**Note:**

- Check Figure 6 and 7 for framing and batten requirements for vertical joint
- For fire rated wall systems by James Hardie nog spacing must be 800mm centres maximum
- For fire resistance rated wall systems, Axon™ Panel must be fixed at 150mm centres to the entire frame. Therefore top/bottom plate and nogs require suitable 150mm sloped cavity packers for the panel fixings